

Model	2-1030-1-000		
Description	LHP-1700FFHC TC-3F		
Cover	S-1167	Revision	
Specs.	110598-2	Revision	
Assembly	1700-B-A23	Revision	A
Installation	1700-B-F8	Revision	A
Wiring	1700-B-E67	Revision	A
Field mounting holes	1700-B-F7	Revision	
Warranty	SK91-05-14A	Revision	

**teca**

TECA Corporation  
Thermoelectric Cooling America  
4048 W. Schubert Ave  
Chicago IL (USA) • 60639  
773-342-4900 • Fax 773-342-0191

Web Site:  
E-mail:

<http://thermoelectric.com>  
[teca@thermoelectric.com](mailto:teca@thermoelectric.com)





Part Number	2-1030-1-000	Model	LHP-1700FFHC
-------------	--------------	-------	--------------


Input Voltage	115 VAC
Current	8.5 Amps RMS
Frequency	50/60 Hz
Nema Type	12
Ambient Range	-30 to +80°C
Weight	21 lbs.
Temperature Control	TC-3F
Cooling Capacity	260-300 Watts
Heating Capacity	400 Watt Heaters Installed
Mounting	See 1700-B-F8
Min. Recommended flow/max. Pressure	0.5 GPM (1.0 Recommended) 60 PSI
Fluid	Fluid with comparable thermal properties to that of water. One that will not react with aluminum with Mil-A-8625D type II Class 2 Anodize
Maintenance	Use clean/filtered fluids for heat exchanger. If process fluid contains deposits, periodic cleaning may be required.

Drawing Number	110598-2
Revision	-

**teca™**

ThermoElectric Cooling America Corporation  
4048 W. Schubert Avenue • Chicago, IL. 60639 • (U.S.A.)  
773-342-4900 Fax • 773-342-0191


LTN	DESCRIPTION	DATE	APPROVED
A	REVISION AND ADDITIONAL DIMENSIONS	01-10-78	IN



NOTE: DIMENSIONS: INCHES  
(MILLIMETERS)

LHP 1700 FF ASSEMBLY		LHP 1700-B-A23	
SCALE 1/4"		SHEET 01	
DRAWING NO.		SHEET 01	
DATE		SHEET 01	
APPROVALS		SHEET 01	
LHP 1700-B-A23		SHEET 01	

APPLICATION			REVISION		
NEXT ASST	USED ON	TIME	DESCRIPTION	DATE	APPROVED
			A. CNGD PIPE FITTING TO ACTION	1-2-36	AP




**INSTALLATION INSTRUCTIONS**

1. Cut and drill mounting holes as per field assembly mounting drawing LHP-1700-B-F7.
  2. Clean mounting surface.
  3. Install unit, use foam weather proofing strips to seal cabinet air tight.
  4. Fit 1" insulation around air conditioner inside of cabinet.
  5. Caulk insulation to seal and secure insulation.
  6. Inspect for air leaks.
  7. Connect 1/4" water lines. (compression fittings) Use one fitting for water inlet, use other fitting for outlet, flow direction does not matter.
  8. Minimum recommended coolant flow rate: 1.9 liter/min. (0.5 gal/min.)
  9. Inspect for water leaks.
  10. Connect power.
- NOTE: Never run unit without water circulation.


THERMOELECTRIC COOLING UNIT AND INSTRUCTIONS FOR FIN AND FAN LHP-1700		CONTRACT NO. APPROVALS DATE 1-6-82		<b>ThermoElectrics</b>	
MATERIAL SEE 2		DRAWING NO. LHP-1700-B-F3		SHEET OF	
DO NOT SCALE DRAWING		SIZE B		SCALE N/A	

ITEM	DESCRIPTION	DATE	APPROVED
1	CORECO BUSSBAR REGISTOR VALVES	07-21-77	A.A.



- INDICATES RED RING TERMINAL
- INDICATES BLUE RING TERMINAL
- ▲ INDICATES RED QUICK CONNECT
- INDICATES BLUE QUICK CONNECT
- INDICATES RED FORK TERMINAL
- INDICATES BLUE FORK TERMINAL
- INDICATES SOLDER CONNECTION

LHP-1700FFHC W/TC-3F WIRING DIAGRAM	
APPROVALS A.A.	DATE 2-14-75
SIZE B	DRAWING NO. LHP1700-B-E67
SCALE D3352	SHEET OF

[illegible]

**T**ECA's products are warranted for a period of one (1) year, from date of shipment from the factory to be free from defects in material and workmanship with correct use, normal operating conditions, and proper application. TECA's obligation under this warranty shall be limited to the repair or exchange (at TECA's option) of any TECA product or part which proves to be defective as provided herein. TECA reserves the right to either inspect the product at buyer's location or require it to be returned to the factory for inspection. Buyer is responsible for freight to the factory on all warranty claims. The above warranty does not extend to goods damaged or subjected to accident, abuse, or misuse after

shipment from the factory, nor to goods altered or repaired by anyone other than specifically authorized by TECA. TECA shall not in any way be responsible for the consequences of any alteration, modification, or misuse unless previously approved in writing by an officer of TECA.

Any description of goods sold hereunder, including any reference to buyer's specifications and any descriptions in catalogs, circulars, and other written material published by TECA, or its agents, is for the sole purpose of identifying such goods and is not an express or implied warranty that the goods shall conform to such description.

Warranty Disclaimer and Limitation of Damages. TECA DISCLAIMS ALL EXPRESS WARRANTIES OTHER THAN THOSE CONTAINED IN THE ABOVE PARAGRAPH AND ALL IMPLIED WARRANTIES, INCLUDING BUT NOT LIMITED TO WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE. TECA SHALL NOT BE LIABLE UNDER ANY CIRCUMSTANCES FOR ANY MONEY DAMAGES OF ANY KIND, INCLUDING BUT NOT LIMITED TO SPECIAL, INDIRECT, INCIDENTAL OR CONSEQUENTIAL DAMAGES, LOST PROFITS, BUSINESS INTERRUPTION, LOSSES, OR LOSS OF BUSINESS OR CUSTOMER RELATIONSHIPS.

Some states do not allow the exclusion of implied warranties or the limitation or exclusion of liability for incidental or consequential damages, so the above exclusion or limitation may not apply to you. This warranty gives you specific legal rights and you may also have other rights that vary from state to state.

#### RETURNED GOODS, RESTOCKING CHARGES

In order to return merchandise for any reason (repair, replacement, or credit) a return authorization number must be issued by TECA. New merchandise may not be returned for credit beyond 60 days from shipment. Charges for incidental or other damage may also be made. All returned goods must be sent freight prepaid. A restocking charge of 15% will apply for standard products.

#### MAINTENANCE

Since the technology is solid-state, there are no filters, compressors, or fluorocarbons to maintain. The only moving parts are the fans used to transfer the energy from the heat sinks. It is recommended, for harsh environments, that the heat sinks be cleaned from time to time. This can be accomplished by directing compressed air over the external fins. This will increase the overall life and performance of the system.

## Mounting Styles

Since there are no fluorocarbons, units can mount in any orientation. Vertical mounting is preferred.




Figure 1

### Vertical (Side/Front/Back) Mounting

A vertical mounting orientation is recommended for applications with high humidity or incomplete cabinet seals. Condensation can be collected from a moisture removal system (standard on FHP-units) or a drip pan positioned below the cold side fins (See Figure 1). Drip pans are optional for thru mount units.

### Condensate Removal System:

All FHP-Series and AHP-1400 air conditioners contain a built-in condensate removal system. The condensate kit consists of a antifungal sponge with a condensate wick. PVC tubing is also provided for drainage.

### Horizontal (Top) Mounting:

It is difficult to collect condensation in this orientation due to the fin orientation and gravity. If a drip pan is employed by the end user, use caution to place the pan far enough away from the internal fan to minimize the restriction of air flow. The pan should cover the fin ends as well as the fan area. When there is a choice, the vertical orientation is preferred by most users.

#### NOTES ON CONDENSATION

Condensation occurs at the cold side fins when the surface temperature goes below the dew point. To reduce or remove condensate, consider the following:



- Regulate the Fin Temperature above the Dewpoint.
- Keep Enclosure Closed and Sealed from Outside Humidity.
- Use Desiccant (Moisture absorbing Granules.)
- Employ Condensate Removal System/Drip Pans.

**teca**

4048 W. Schubert Ave. • Chicago IL (U.S.A.) • 60639  
773-342-4900 • Fax • 773-342-0191

Drawing # 100-000000